



VIRTUE^{S.A.L.}

Grow by Virtue of Efficiency

Analysis and Evaluation Sheet

Aircosaver Version 4.1

Company Name

Al Baba Sweets
Saida-Lebanon

Unit Information from nameplate

Make:	Line Voltage: 3 380 V
COOLER	
Tower Type	Phasing: Three
Tonnage or BTU :	60 Th. BTU Power: 4.5 KW

Installation Address :

Warehouse

24 HRS Test Without Aircosaver

Beg.Date and Time Sunday 29 April 2012 13:00
End Date and Time Monday 30 April 2012 13:00

24 HRS Test With Aircosaver

Beg.Date and Time Friday 27 April 2012 13:00
End Date and Time Sat 28 April 2012 13:00

Thermostat set Point

Setting Inside 15 Degree Celsius

Thermostat set Point

Setting Inside 15 Degree Celsius

Inside Temperature

Average	18.71	Celsius
Minimum	17.89	Celsius
Maximum	19.22	Celsius

Inside Temperature

Average	17.86	Celsius
Minimum	17.44	Celsius
Maximum	18.67	Celsius

Power Consumption (KWH)

54.53 KWH

Power Consumption (KWH)

39.58 KWH

Saving in KWH

14.94 KWH

Saving %

27%

Data Collected ON April 30 ,2012

Report Prepared on : April 30 , 2012

Witness by Company :

Name: _____

Position : _____

Date : _____

Signature : _____

Witness by VIRTUE S.A.L. :

Name: _____

Position : _____

Date : _____

Signature : _____