

DATE: February 6, 2013

TEST NO: 1

### COMPANY DETAILS:

**Company Name:** Geofman Pharmaceuticals (Pvt.) Ltd.  
**Contact Person:** Mr. M. Sadiq Shaikh  
**Designation:** Partner  
**Address:** Plot No.20, Sector-23, Korangi Industrial Area, Karachi  
**Contact Details:** 35062185, 35073576, 35062187, 35050740

### INSTALLATION DETAILS:

**Make:** Cool Point  
**Type:** Package Unit  
**Capacity:** 4 Ton  
**Line Voltage:** 220 V  
**Location:** Tablet Section

### TEST RESULTS

#### Without AircoSaver

	Date	Time	Temp	Units
Start	23-Jan	1:45 PM	20 C	1.45
Stop	23-Jan	3:25 PM	20 C	13.8
Total		1:40		12.35

Units Consumed per Hour: 7.41 KWH

#### With AircoSaver

	Date	Time	Temp	Units
Start	23-Jan	4:40 PM	20 C	16.8
Stop	23-Jan	6:22 PM	20 C	26.8
Total				10

Units Consumed per Hour: 5.88 KWH

SAVINGS in KWH: 1.53

SAVINGS in %: 20.64 %

CLIENT ACKNOWLEDGEMENT

FOR ENERTECH