

DATE: July 18, 2012

TEST NO: 01

COMPANY DETAILS:

Company Name: Outsource World
Contact Person: Mr. Mughal, Mr. Rashid
Designation: Facilities Incharge
Address: Suite No. 104 & 207, Tariq Center, Tariq Road, Karachi.
Contact Details: 0092-21-34524115-8

INSTALLATION DETAILS:

Make: Mitsubishi
Type: Split
Capacity: 2 Ton
Line Voltage: 220 V, Single Phase

TEST RESULTS

Without AircoSaver

	Date	Time	Temp	Units
Start	7-JUL	5:14	20°C	186.710
Stop	7-JUL	9:14	20°C	195.219
Total		4 Hrs		8.509

Units Consumed per Hour: 2.127

With AircoSaver

	Date	Time	Temp	Units
Start	9-JUL	5:00	20°C	195.219
Stop	9-JUL	9:00	20°C	210.215
Total				5.906

Units Consumed per Hour: 1.4765

SAVINGS in KWH: 0.65

SAVINGS in %: 30.5%



CLIENT ACKNOWLEDGEMENT

[Handwritten Signature]
28/7/12

[Handwritten Signature]
28/7/12

FOR ENERTECH