

DATE: November 12, 2012  
TEST NO: 01

### COMPANY DETAILS:

Company Name: Workforce Software  
Contact Person: Mr. Abbas Paliwala  
Designation: Operations Manager  
Address: 101, Business Center, Main Sharah-e-Faisal, Karachi  
Contact Details: 92-21-34324323-4

### INSTALLATION DETAILS:

Make: Mitsubishi Heavy Industries  
Type: Split  
Capacity: 1.5 Ton  
Line Voltage: 220 V, Single Phase

### TEST RESULTS

#### Without AircoSaver

	Date	Time	Temp	Units
Start	2-Nov	2:50 PM	26C	505.525
Stop	2-Nov	6:20 PM	26C	510.02
Total		3:30 Hr		4.495

Units Consumed per Hour: 1.284

#### With AircoSaver

	Date	Time	Temp	Units
Start	5-Nov	2:50 PM	26C	548.29
Stop	5-Nov	6:20 PM	26C	550.619
Total		3:30 Hr		2.329

Units Consumed per Hour: 0.665

SAVINGS in KWH: 0.6185 KWH/Hr

SAVINGS in %: 48.21%

Workforce Software Development  
(Private) Limited



Chief Executive/Director

CLIENT ACKNOWLEDGEMENT

19-Nov-2012



FOR ENERTECH