

01 April 2013

Subject: Summary of results from meter SN 30531576

The meter data extracted from the above meter provides consumption data. The data collected covers the following periods:

1st week (Mon. 4 March 2013 to Tue. 12 March 2013) with AircoSaver fitted


2nd week (Tue. 12 March 2013 to Tue. 19 March 2013) without AircoSaver

One air conditioning unit used: 12 000 BTU Split unit in Electricity Department Office, Nelson Mandela Metropolitan Municipality

D/T no Airco	kWh no Airco	kWh with Airco	D/T with Airco	Difference	% Saving
13/03/13	9.93	9.24	07/03/13	-0.69	-7%
14/03/13	4.48	2.9	08/03/13	-1.58	-35%
17/03/13	8.02	5.79	09/03/13	-2.23	-28%
18/03/13	8.17	5.55	10/03/13	-2.62	-32%
					-26%

The results show an average saving of 26%.

Regards,



Jens Stratenwerth