

DATE: July 18, 2012

TEST NO: 02

COMPANY DETAILS:

Company Name: Outsource World
Contact Person: Mr. Mughal, Mr. Rashid
Designation: Facilities Incharge
Address: Suite No. 104 & 207, Tariq Center, Tariq Road, Karachi.
Contact Details: 0092-21-34524115-8

INSTALLATION DETAILS:

Make: Mitsubishi
Type: Split
Capacity: 2 Ton
Line Voltage: 220 V, Single Phase

TEST RESULTS

Without AircoSaver

	Date	Time	Temp	Units
Start	11-JUN	12:55PM	23°C	251.443
Stop	11-JUN	6:20PM	23°C	263.350
Total		5:25Hr		11.907

Units Consumed per Hour: 2.198

With AircoSaver

	Date	Time	Temp	Units
Start	10-JUN	8:20PM	23°C	228.560
Stop	11-JUN	12:40PM	23°C	251.443
Total		6:20Hr		12.883

Units Consumed per Hour: 0.788

SAVINGS in KWH: 1.41

SAVINGS in %: 64.1%



CLIENT ACKNOWLEDGEMENT

[Handwritten Signature]
28/7/12

[Handwritten Signature]
28/7/12

FOR ENERTECH