

Date: 02/12/2008

To,
Mr. Dileep Patel
Managing Director
Ecopower pvt. Ltd.
105, Neelkanth,
98, Marine Drive
Mumbai 400002

Dear Sir,

**AIRCOSAVER ENERGY SAVING TEST FOR AIR CONDITIONERS
CARRIED OUT AT YOUR PSYCHROMETRIC LAB. NOVEMBER 19,2008
TO NOVEMBER 21,2008.**


With reference to the discussion with Mr. Behram Dubash and as decided, 8 hours test were carried on window air conditioner in our Psychometric lab from 19 Nov to 21 Nov on two versions of Aircosaver unit. Following observations were recorded.

	As on 19 to 21 Nov	As on 23 to 25 September
AC used for testing	1.2 TR Window AC	1.5 TR Split AC
Without energy saver	6.075	6.9
With 3.5 unit	4.876	5.7
With 3.7 unit	4.828	5.2
% saving with 3.5 unit	19.74	17.39
% saving with 3.7 unit	20.53	24.63

The above results depict that current results are inline with previous results that is power saving with version 3.7 unit is more than power saving with version 3.5 unit.

For your reference: Attached temperature graphs.

Regards,


B.J. Wadia
Executive Vice President
Innovation, technology & Engineering
Appliance Division

Godrej